

## COMMERCIAL ASME POOL HEATERS - CODE DESCRIPTIONS

### G-1 CSD-1 Code (Control and Safety Devices)

<b>Size 514-824</b> Includes: <ul style="list-style-type: none"> <li>➤ Manual Gas Valve</li> <li>➤ Pilot "B" Valve</li> <li>➤ Pilot Solenoid Valve</li> <li>➤ Pilot Regulator</li> <li>➤ Leak Test Valves</li> <li>➤ Flow Switch - Loose</li> </ul>	<b>Size 926-1223</b> Includes: <ul style="list-style-type: none"> <li>➤ Manual Gas Valve</li> <li>➤ Pilot "B" Valve</li> <li>➤ Leak Test Valve</li> <li>➤ Flow Switch - Loose</li> </ul> <p><b>NOTE:</b> Gas connector size may increase on some units by one size.</p>
<b>Size 1287-2500</b> Includes: <ul style="list-style-type: none"> <li>➤ Manual Gas Valve</li> <li>➤ Leak Test Valves</li> </ul> <p><b>NOTE:</b> Gas connector size may increase on some units by one size.</p>	<b>Size 3001-4001</b> Includes: <ul style="list-style-type: none"> <li>➤ Manual Gas Valve</li> <li>➤ Leak Test Valves</li> <li>➤ Low Gas Pressure Switch</li> </ul> <p><b>NOTE:</b> Size 3500 gas connector size changes to 2 1/2".</p>

### STATES REQUIRING CSD-1

Arkansas	Illinois	Montana	Rhode Island
Arizona	Idaho	Nebraska	South Dakota
Colorado	Kansas	Nevada	Tennessee
Connecticut	Maryland	New Jersey	Utah
Delaware	Massachusetts	New Mexico	Vermont
Dist. Of Columbia	Michigan	New York	Virginia
Florida	Minnesota	North Dakota	Washington
Georgia	Missouri	Oklahoma	West Virginia
Hawaii		Oregon	
<b>Other organizations:</b> US Bureau of Indian Affairs US Coast Guard US Post Office		<b>Other Areas:</b> British Columbia Manitoba New Brunswick	

**NOTE:** These are the known States that currently require CSD-1. Other States may be added without our knowledge.

### G-4 Illinois School Code (BOCA Code)

<b>Includes:</b> <ul style="list-style-type: none"> <li>➤ F-9 Low Water Cutoff</li> <li>➤ Temperature Limiting Control</li> </ul>
---

#### G-7 New Mexico Code G-8 Washington State Code

<b>Size 514-4001</b> Includes: <ul style="list-style-type: none"> <li>➤ Same as G-1 CSD-1</li> </ul>	<b>Sizes: 514-4001</b> Includes: <ul style="list-style-type: none"> <li>➤ Low Water Cutoff</li> </ul>
---	--

**NOTE:** Seattle, Washington: Require Flow Switch to be mounted on the outlet of the pool heater.